TORNADO AND EXTREME WIND
DESIGN CRITERIA FOR
NUCLEAR POWER PLANTS

BECHTEL POWER CORPORATION
SAN FRANCISCO, CALIFORNIA

DISCLAIMER

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

CAVEAT: THIS REPORT HAS BEEN PREPARED BY AND FOR
            THE USE OF BECHTEL POWER CORPORATION AND
            ITS RELATED ENTITIES. ITS USE BY OTHERS
            IS PERMITTED ONLY ON THE UNDERSTANDING
            THAT THERE ARE NO REPRESENTATIONS OR
            WARRANTIES, EXPRESSED OR IMPLIED, AS TO
            THE VALIDITY OF THE INFORMATION OR
            CONCLUSIONS CONTAINED HEREIN.

TOPICAL REPORT

BC-TOP-3-A

REVISION 3

TORNADO AND EXTREME WIND /

DESIGN CRITERIA FOR

NUCLEAR POWER PLANTS

Prepared by:

J. V. Rotz

G. C. K. Yeh

W. Bertwell

Approved by:

H. W. Wahl

Chief Civil Engineer

Thermal Power Organization

Bechtel Power Corporation   Issue Date: August 1974

UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

UPI   4 1974

Mr. John V. Morowski
Vice President-Engineering
Bechtel Power Corporation
Fifty Beale Street
San Francisco, California   94119

Dear Mr. Morowski:

The Regulatory staff has completed its review of Bechtel Power
Corporation's Topical Report, BC-TOP-3, Revision 3, dated August
1974 and entitled "Tornado and Extreme Wind Design Criteria for
Nuclear Power Plants". We conclude that the design criteria and
procedures described by this report are acceptable to the Regulatory
staff and that BC-TOP-3, Revision 3, is acceptable by reference in
applications for construction permits and operating licenses. A
summary of our evaluation is enclosed.

BC-TOP-3 does not provide all of the pertinent tornado and extreme
wind information required by the Regulatory staff in its review of
specific applications. Therefore, the supplementary information
identified in the Regulatory Position of the enclosed Topical Report
Evaluation will have to be provided in individual Safety Analysis
Reports.

The staff does not intend to repeat its review of BC-TOP-3, Revision
3, when it appears as a reference in a particular license application.
Should Regulatory criteria or regulations change, such that our
conclusions concerning BC-TOP-3, Revision 3, are invalidated, you
will be notified and given the opportunity to revise and resubmit
your topical report for review, should you so desire.

We request that you reissue BC-TOP-3, Revision 3, dated August 1974 in accordance with the provisions of the "Elements of the Regulatory Staff Topical Report Review Program" which was forwarded to you on August 26, 1974. If you have any questions in this regard, please let us know.

Sincerely,

R. W. Klecker, Technical Coordinator
    for Light Water Reactors, Group 1
Directorate of Licensing

Enclosure:
Topical Report Evaluation

TOPICAL REPORT EVALUATION

Report No.: BC-TOP-3 Rev. 3
Report Title: Tornado and Extreme Wind Design Criteria for Nuclear
              Power Plants
Report Date: August 1974
Originating Organization: Bechtel Power Corporation
Reviewed by: Structural Engineering Branch, Site Analysis Branch
             and Auxiliary Power and Conversion System Branch, all
             of Directorate of Licensing, September 1974

SUMMARY OF REPORT

This report contains criteria for design of nuclear power plant
structures for extreme winds and tornado effects. Extreme wind
criteria cover wind velocities up to and including hurricanes. The
extreme wind velocities specified herein, are identical to those
defined by wind speed map of ANSI Building Code requirements A58.
1-1972. The velocities defined correspond to a mean recurrence
interval of 100 years.

Extreme wind loading is applied to structures using methods and
procedures consistent with the ANSI Code. The wind load provisions of
the ANSI Code, as modified herein, are an essential part of these
criteria. Combinations of extreme wind loads with other loads
and maximum allowable values of stress and strain are not included
in the report. This information will be specified in individual
plant SAR.

For the parameters defining tornado size, intensity, loading, de-
pressurization characteristics and others, the report refers to the
plant SAR.

Velocity pressures resulting from tornado winds are applied using
procedures paralleling those for extreme winds, the primary differ-
ences being the treatment of the tornado horizontal and vertical
pressure profiles as opposed to those considered in extreme wind
design. To facilitate use of the material contained in the ANSI
Code, parallel definitions of velocity pressures for determining
overall loading, local loading and internal pressures have been
developed.

In addition to velocity pressure loading, methods and procedures for determining the magnitude and combined effects of atmospheric pressure change and tornado missile impact are included.

For the load combinations involving tornado effects, and associated design allowables the report refers to individual plant SAR. For structures with no openings, differential pressures due to full and partial effects of atmospheric pressure change are considered in design. For structures with openings (vented) the differential pressure loading is calculated using Bechtel computer program CE 899. Differential pressures on exterior walls calculated by the code (one dimensional analysis) are to be multiplied by a 1.20 factor of safety to account for possible non-conservatism due to the three-dimensional flow effects.

A cross-reference listing of items in this report related to Atomic Energy Commission Safety Analysis Report format is provided in Appendix A. Symbols and notations that are generally consistent with those adopted by the ANSI Code are contained in Appendix B. Development of supporting tornado criteria is included in Appendix C. Appendix D describes a one dimensional computer program for calculating building depressurization effects and references are contained in Appendix E.

SUMMARY OF THE REGULATORY EVALUATION

The Structural Engineering, Site Analysis and Auxiliary Power and Conversion Systems Branches of the Directorate of Licensing have reviewed the subject report, including Appendices A, B, C and D. The procedures covered by this report with augmentation of pertinent information that is referred to and to be provided in plant SAR, are judged to represent the present "state of the art" in the field of design of structures against wind and tornado loadings. If properly utilized in nuclear power plant structural design work, the

procedures and criteria contained in the report should provide conservative and acceptable bases for design of nuclear power plant structures.

REGULATORY POSITION

The design criteria and procedures described by this report are acceptable to the Regulatory Staff. The report may be referenced in future case applications provided that the following specific information reviewed and accepted by the Regulatory Staff is included in individual SAR:

a. Parameters that define tornado loading, such as, translational and maximum tornado wind velocities, rate of depressurization, radius of maximum tornado wind velocity and amplitude of maximum pressure drop, etc.

b. Applicable wind velocities higher than those shown in Fig. 2 of the report as required by unique site conditions.

c. Combinations of extreme wind loads, W, with other loads and maximum allowable stress and strain.

d. A list of Category I and non-Category I structures, systems and components to which extreme wind design criteria are applied.

e. A list of all safety-related structures that are to be designed to resist the effects of tornadoes.

TOPICAL REPORT

BC-TOP-3

TORNADO AND EXTREME WIND

DESIGN CRITERIA FOR

NUCLEAR POWER PLANTS

ABSTRACT

This report contains nuclear power plant design criteria
for tornadoes and extreme winds. It includes data, formu-
lation and procedures for determining maximum wind loading on
structures and parts of structures.

Extreme wind loading is applied to structures using methods
and procedures consistent with the ANSI Building Code require-
ments A58.1-1972 (Ref. 1). The basic design wind velocities
are defined by the wind speed map, Fig. 2-1 (from Ref. 1,
Fig. 2) for 100-year mean recurrence interval winds. | 3

Tornado wind loading is applied to structures using procedures
paralleling those for extreme winds with additional criteria
resulting from the atmospheric pressure change accompanying
tornadoes and tornado missile impact effects.

Parameters (velocities, pressure drop and geometry) defining
the magnitude of the tornado upon which plant design is based | 3
are specified in the plant Safety Analysis Report (SAR).

A cross reference listing of items in this report related to | 3
Atomic Energy Commission Safety Analysis Report format is pro-
vided in Appendix A. Development supporting tornado criteria
is included in Appendix C and Appendix D. | 3

TABLE OF CONTENTS

APPENDICES

LIST OF FIGURES

3

1.0 INTRODUCTION

This report contains criteria for design of nuclear
power plant structures for extreme winds and torando
effects. Extreme wind criteria cover wind velocities
up to and including hurricanes. The extreme wind
velocities specified herein (defined by wind speed
map, Fig. 2-1 from ANSI Building Code requirements
A58.1-1972, Fig. 2, Ref. 1) correspond to a mean
recurrence interval of 100 years.

|3

Extreme wind loading is applied to structures using
methods and procedures consistent with Ref. 1. The
wind load provisions of Ref. 1, as modified herein,
are an essential part of these criteria. Although
it is assumed in this report that the reader (or user)
is thoroughly familiar with the provisions contained in
Ref. 1, additional data and explanatory material are
included to facilitate application of these provisions.

|3

Parameters defining tornado loading are specified in
the plant SAR.

|3

Velocity pressures resulting from tornado winds are
applied using procedures paralleling those for extreme
winds, the primary differences being the treatment of
the tornado horizontal and vertical pressure profiles
as opposed to those considered in extreme wind design.
To facilitate use of the material contained in Ref. 1,
parallel definitions of velocity pressures for deter-
mining overall loading, local loading and internal
pressures have been developed.

In addition to velocity pressure loading, methods and
procedures for determining the magnitude and combined
effects of atmospheric pressure change and tornado
missile impact are included along with special consider-
ations peculiar to nuclear power plant facilities.

A cross-reference listing of items in this report related |3
to Atomic Energy Commission Safety Analysis Report for-
mat is provided in Appendix A. Symbols and notation con-
sistent with this report and Ref. 1 are contained in
Appendix B. Development supporting tornado criteria is
included in Appendix C. Appendix D describes a computer
program for calculating building depressurization and
references are contained in Appendix E.

2.0 EXTREME WINDS

2.1 Extreme Wind Phenomena

Extreme winds are defined for the purpose of this
document as winds with a vertical gradient, occurr-
ing over a wide area, and having velocities up to |3
and including hurricane intensity.

The 100-year mean recurrence interval extreme winds
in these design criteria (Fig. 2-1) are based on the
data in "Climatological Data, National Summaries" from
the U. S. Weather Bureau. If local conditions indi- |3
cate higher wind velocities than shown in Fig. 2-1,
such velocities will be addressed in the SAR. Local
conditions, if more severe, shall govern.

2.2 Basic Wind Velocities

The basic design wind speeds are shown in Fig. 2-1.
Criteria for surburban areas and cities are generally
less severe, but are not used in the design of nuclear |3
plants regardless of plant location.

2.3 General Provisions

Extreme wind design criteria are applied to Category
I and non-Category I structures, systems, and components
as defined in Ref. 4 and listed in the plant SAR.
These structures are designed for the basic wind ve-
locities shown by Fig. 2-1. Except as otherwise
noted herein, the provisions of Ref. 1 for Exposure C
(flat, open terrain) shall be followed in applying |3
extreme wind loads.

Other structures are designed in accordance with |3
local or regional governing building codes, if so
provided in the project design criteria, or in compli- |3
ance with Ref. 1, whichever is the more severe.

2.4 Special Considerations

The effective velocity pressures given in Table 5 of Ref. 1 take into account the dynamic response to gusts of ordinary buildings and structures in a direction parallel to the wind and should be considered minimum. Design of structures subject to dynamic excitation, such as vortex shedding from chimneys, shall be based on a detailed dynamic investigation. (See Section 6.3.4.1 of Appendix A of Ref. 1, and Ref. 5.) | 3

2.5 Load Combinations

Combinations of extreme wind loads, W, with other loads, and maximum allowable values of stress and strain, are specified in the plant Safety Analysis Report (SAR).

Figure 2-1   Basic Wind Velocity, V_{30}(mph) — 100-Year Mean
Recurrence Interval (from Ref. 1)

3.0 TORNADOES

3.1 Tornado Phenomena

Tornadoes are highly localized wind storms characterized by high velocity winds varying in intensity with the radial distance from the center or axis of the tornado.

For developing structural design criteria, a single vortex tornado is considered. Maximum wind velocity occurs at a distance from the center of the tornado, called the radius of maximum wind, R_m. Wind velocity increases with distance from the center to the radius of maximum wind, beyond which velocity decreases, varying | 3 inversely with the radius. This results in a horizontal velocity pressure profile peaking at the radius of maximum wind. Wind velocity also varies with height, but to a much lesser degree than the horizontal variation with radius. The vertical velocity pressure profile is assumed to be uniform. Design velocity pressure loading from tornado winds (W_{tq}) is therefore based on the horizontal pressure profile.

The rotational motion of the air mass about the center of a tornado produces a pronounced change in atmospheric pressure which can, in the case of closed or partially vented structures, produce additional direct differential pressure loading (W_{tp}) as the tornado passes over a structure. This change is minimal at the outer periphery of the tornado and reaches a maximum at its center.

Tornado-resistant structures must also be designed to resist missile impact effects from airborne objects and debris (from failed or damaged structures and equipment) which are transported by tornado winds. Due to the rotary motion of the tornado winds, missiles tend to be ejected from the tornado and generally reach maximum velocities in the vicinity of or beyond the radius of maximum wind. For design purposes, tornado missile impact effects are therefore considered separately or concurrent with velocity pressure and atmospheric pressure change effects at the radius of maximum wind.

Tornadoes vary in size, configuration, intensity and frequency of occurrence depending on local and regional meteorological and topographical conditions. The largest number and most severe tornadoes occur in the eastern portion of the United States. Smaller and less severe

tornadoes have occurred infrequently in isolated portions of the western coastal states. Present storm data are insufficient to determine which areas are not susceptible to tornadoes. Therefore, in the absence of a detailed meteorological investigation for a particular plant location, tornadoes are assumed to occur anywhere within the 48 contiguous United States.

Parameters defining the tornado size, intensity, and characteristics are defined in the SAR for each plant. |3

3.2 General Provisions

All safety-related structures that are to be designed to resist the effects of tornadoes will be listed in |3 the plant SAR. All safety-related equipment systems and components shall either be designed to sustain tornado effects without loss of function or shall be protected by a tornado-resistant structure. Other structures and plant equipment shall also be designed or protected so that they will not jeopardize the integrity or function of Category I structural systems or components or safety-related equipment by virtue |3 of collapse or detachment of component parts.

3.3 Tornado Design Parameters

3.3.1 Maximum Wind Velocities

Due to rapid developments in tornado technology, parameters defining maximum wind velocities and geometrical features of the design basis tornado |3 model will be specified in the SAR.

3.3.2 Atmospheric Pressure Change

The maximum magnitude and rate of atmospheric pressure change are specified in the plant SAR. |3

For determining the differential pressure loading resulting from atmospheric pressure change, the idealized pressure-time function shown in Fig. 3-1 can be used in lieu of the more representative formulae contained in Appendix C. However, use of the formulation in Appendix C is preferred where computational difficulties are not a factor. |3

3.3.3 Tornado Missiles

The tornado missiles to be considered in plant design are identified and characterized in the plant SAR.

3.4 Load Combinations

The load combinations involving tornado effects, W_t, and associated design allowables are specified in the plant SAR.

W_t is further defined by the following load equations:

$$W_t = W_{tq} \tag{Eq. 3-1}$$
$$W_t = W_{tp} \tag{Eq. 3-2}$$
$$W_t = W_{tm} \tag{Eq. 3-3}$$
$$W_t = W_{tq} + 0.5 \, W_{tp} \tag{Eq. 3-4}$$
$$W_t = W_{tq} + W_{tm} \tag{Eq. 3-5}$$
$$W_t = W_{tq} + 0.5 \, W_{tp} + W_{tm} \tag{Eq. 3-6}$$

W_{tq} = Velocity pressure effects

W_{tp} = Atmospheric pressure change effects

> Calculated differential pressures (using procedures described in Appendix D) on exterior walls shall be multiplied by a factor of 1.2. |3

W_{tm} = Missile impact effects

For discussion and derivations supporting these load combinations, see Appendix C.

3.5 Load Determination

3.5.1 Velocity Pressure Loading

Velocity pressure loading, W_{tq}, is determined using the methods and procedures contained in Ref. 1 with the following exceptions:

1. Velocity and velocity pressure are assumed not to vary with height.

2. Velocity and velocity pressure vary with horizontal distance from the center of the tornado. For definition of horizontal pressure profile, see Fig. 3-2. |3

3. Velocity pressures q_F, q_P, and q_M are determined in accordance with Section 3.5.1.1

4. Criteria for determining velocity pressures for parts and portions (par. 6.3.4.2 of Ref. 1) are not applicable.

5. Gust factor is taken as unity.

3.5.1.1 Velocity Pressures

Velocity pressures are determined by multiplying the velocity pressure, P_{max}, at the radius of maximum wind, by the size coefficient, C_s, defined in Fig. 3-3 (for development of Fig. 3-3 |3 see Appendix C).

$$q = C_s P_{max} \qquad \text{(Eq. 3-7)}$$

$$q = q_F, \; q_p \text{ or } q_M$$

q_F = Velocity pressure for overall structural response (psf)

q_p = Velocity pressure for parts and portions (psf)

q_M = Velocity pressure for calculating internal pressures (psf)

P_{max} = Velocity pressure at the radius of maximum wind (psf)

$$P_{max} = 0.00256 V^2_{max} \qquad \text{(Eq. 3-8)}$$

V_{max} = Maximum design wind velocity as determined by Section 3.3.1 (mph)

For q_F and q_p, C_s is determined as follows:

1. Determine the load distribution length, L, of the structure or structural element. Length L is the plan distance perpendicular to the direction of the wind over which the wind load can be distributed, (such as by beam, truss, or horizontal diaphragm action) or the mean horizontal extent of the tributary area perpendicular to the direction of the wind.

2. Determine the ratio of length, L, to radius of maximum wind, R_m. (The value of R_m is specified in the plant SAR.) |3

3. Enter Fig. 3-3 with L/R_m and read value of C_s. |3

The internal velocity pressure, q_M, depends on the location and distribution of openings. When the size and distribution of openings are relatively uniform around the periphery of the structure, q_M is determined from Eq. 3-7 using a value of L equal to the plan dimension of the structure perpendicular to the wind and the same procedure as for external velocity pressures. For unequal size and distribution of openings, q_M is determined from Eq. 3-7 using the following weighted average technique to determine C_s.

1. Locate structure within the pressure profile for maximum total wind load by determining the values of r_1 and r_2 which satisfy Eq. 3-9:

$$\frac{r_1}{R_m} = \frac{R_m}{r_2} \qquad \text{(Eq. 3-9)}$$

$$L = r_2 - r_1 \quad \text{(see Fig. 3-3)}$$

L = Plan dimension of structure perpendicular to wind direction

2. Determine velocity pressure factor C_q from Fig. 3-2 for each exposed opening.

3. Determine C_s from Eq. 3-10.

$$C_s = \frac{\sum\limits_{1}^{N} A_{oi} C_{qi}}{\sum\limits_{1}^{N} A_{oi}} \qquad \text{(Eq. 3-10)}$$

A_{oi} = Area of opening at location i

C_{qi} = Velocity pressure factor at location i

N = Number of openings

3.5.2 Atmospheric Pressure Change Loading

For structures with no openings (unvented), differential pressures due to atmospheric pressure change are applied in accordance with Eqs. 3-2, 3-4, and 3-6 with the atmospheric differential pressure tending to force external surfaces outward.

For structures with openings (vented) the differential pressure loading is calculated using a pressure-time function as described in Section 3.3.2. Bechtel computer program CE 899 described in Appendix D can be utilized for performing these calculations. Structures with a vent area to compartment volume ratio greater than that of a structure sustaining a maximum differential pressure of 10 psf during the assumed tornado can be considered fully vented. | 3

Differential pressures on exterior walls calculated by procedures contained in Appendix D (CE 899) are multiplied by a factor of 1.2. | 3

3.5.3 Missile Impact Effects

Missile impact effects are evaluated using the methods and procedures contained in Ref. 3.

3.6 Special Considerations

3.6.1 Differential Pressures On Internal Components

Internal components (such as tankage, ventilation ducts and equipment, walls, floors, partitions, etc.) must be provided with adequate venting or must be designed for differential pressures resulting from building pressurization and depressurization.

Vents and openings must be located and sized such that exit and entrance velocities will not jeopardize the functional capability of other internal safety-related equipment and components.

3.6.2 Protection Of Exterior Openings

Exterior openings and vents in structures required to provide missile protection shall be designed such as to preclude entrance of tornado missiles.

3.6.3 Special Shapes

Lift, drag and/or pressure coefficients for structures or structural elements whose shape and geometry differ appreciably from those of regular buildings and components such as covered in Ref. 1 may be based on well-documented data such as those contained in Ref. 2. For example, Fig. 4-3, based on Table 4(f) of Ref. 2 can be used to determine wind loads and pressure distribution on containment structures. | 3

Where such data are not available or cannot be developed analytically, special tests are required.

3.6.4 Dynamic Excitation

Design of wind sensitive structures as defined in Ref. 1 and structures subject to dynamic excitation, such as from flutter, gallop and vortex shedding, shall be based on a dynamic investigation such as outlined in Section A6.3.4.1 of Ref. 1 and papers listed in Ref. 1.

| 3

3.6.5 Limited Damage

Structures may sustain limited damage if such damage does not hazard the integrity or functional capability of Category I structures or equipment.

3.6.5.1 Missile Damage

Tornado resistant structures may sustain local missile damage such as partial penetration and local cracking and/or permanent deformation provided that structural integrity is maintained, perforation is precluded and contained Category I equipment is not subjected to damage by secondary missiles, such as from concrete spalling.

| 3

| 3

3.6.5.2 Loss Of Sheathing

Exterior sheathing and nonstructural walls and partitions of structures not required to protect interior systems and components from tornado effects may be considered expendable and allowed to become detached or fail during a tornado, provided such detachment or failure does not constitute a more serious missile hazard than that of the tornado design missiles specified in the SAR.

The structural frame of such structures shall be designed to sustain 1.5 times the pressure at which the sheathing is expected to fail. This loading need not exceed the full pressure loading. These structures shall also be designed for tornado winds acting on the projected area of exposed members and equipment, assuming (for conventional three-span sheathing) one-third of the sheathing remains on the windward portion of the building. Sheathing which is supported by more than four girts or purlins will be treated on a special case basis.*

| 3

---

*Previous analyses and observations have indicated no significant difference in wind load on frames where special sheathing has been used. However, this check shall be made to confirm the adequacy of the structure.

| 3

The tributary load from expendable interior non-structural walls and partitions shall be taken as 1.5 times the pressure loading at which they are expected to fail, but need not exceed full tornado velocity pressure loading.

3.6.5.3   Cranes

Cranes exposed to tornado winds by virtue of loss of expendable sheathing may sustain functional damage but shall be designed to remain on the runway girders so as not to hazard tornado-resistant structures or Category I systems and components.

3.6.5.4   Other Structures

The design or location of other structures not designated as tornado-resistant structures shall be such as not to hazard tornado-resistant structures or protected equipment by virtue of collapse or generation of missiles (more severe than those specified in the SAR) from detached portions or contained equipment.

3.6.6   Exposed Category I Bodies Of Water

Design of small exposed Category I bodies of water (such as the fuel pool) shall consider a water loss amounting to a change in water level of two feet. |3

Larger exposed bodies of water (such as spray ponds) |3 shall be designed such that water can be supplied from an alternative source on an as-needed basis or shall be tied in with redundant facilities to maintain functional capability. This interim provision will be followed until further investigation enables a closer evaluation of potential water loss. Water transport by tornadoes is discussed in Refs. 7, 8 and 9.

Note: Trapezoidal Approximation of the Theoretical
Curve Derived from a Combined Rankine Vortex
Velocity Pressure Profile (see Fig. C1-1).
For notation see Appendix B.

FIGURE 3-1   Idealized Atmospheric Pressure Change Vs.
Time Function

FIGURE 3-2   Velocity Pressure Variation With Radius From Center Of Tornado

FIGURE 3-3   Size Coefficient, C_s , For Average Tornado Velocity Pressure Loading

4.0 EXAMPLES AND ILLUSTRATIONS

4.1 Velocity Pressure Coefficients

Velocity pressure coefficients are applicable to both extreme winds and tornado winds. Figs. 4-1 and 4-2 illustrate applications of local external pressure coefficients $C_{\bar{p}_{local}}$ for walls and roofs (Ref. 1).

Local increased loads are applied individually, and not simultaneously with the net external pressures when computing overall loads, nor simultaneously with overlapping local increased loads as at eaves and eave intersections.

An illustration of pressures acting on an overhanging eave is shown in Fig. 4-2. Where the walls extend upward above the roof as parapets, C_p for the outer parapet face shall be the same as for the wall, and $C_{p_{local}}$ for the inner face of the parapet shall be -2.4.

The width of strips subjected to local increased loads need not exceed 12 feet.

Figure 4-3 illustrates the external pressure distribution on cylinders and spheres (Ref. 2) which can be used in the analysis of wind loads on containment structures. Figure 4-4 illustrates the variation of drag coefficient, C_D, with aspect ratio (ratio of length to width). This figure is applicable to suspended rectangular members (such as structural shapes). If flow around the ends of a member is inhibited such as by other framing members, the length is considered infinite and a drag coefficient of 2 is used. | 3

4.2 Extreme Wind Velocity Pressures

Figure 4-5 illustrates application of extreme wind velocity pressures on a typical building. Pressure coefficients, C_p and C_{pi}, correspond to a structure with uniformly distributed openings and height-to-width and height-to-length ratios less than 2.5. The variation of velocity pressure with height is also shown schematically. The corresponding variation of internal pressures assumes negligible vertical venting between floors.

4.3   Tornado Pressure Loading

The following example illustrates determination of tornado pressure loading. The steel frame structure shown below is subjected to a tornado with winds from either direction, A or B. For illustrative purposes only, R_m, V_{max}, V_{tr}, and ΔP_a have been assumed to be 275 ft., 360 mph, 60 mph and 432 psf, respectively.* |3

AREA OF OPENING = 1000 FT^2
WALL AREA   = 30,000 FT^2

The structure has a horizontal roof truss system, which transmits wind loads to bracing in the side and end walls. Purlins are parallel to the side walls, roof girders span the strucuture in the short direction and bay spacing is 25 feet.

4.3.1   Velocity Pressures

The following effective velocity pressures, q_F, q_P |3 and q_M for the various structural components and systems were determined using the criteria in Section 3.5.1.1 and Fig. 3-3. |3

---

*The values of R_m, V_{max}, V_{tr}, and ΔP_a to be used in design shall be obtained from the plant SAR. |3

For Internal Pressure	Wind Direction	L (ft)	C_s	Effective Velocity Pressure (psf) |3
	A	200	.73	$q_M = 240$
	B	100	.83	$q_M = 275$
For Sheathing	A&B	0	1.00	$q_P = 330$
Roof Truss	A	200	.73	$q_F = 240$
	B	100	.83	$q_F = 275$
100' Wall Bracing	A	200	.73	$q_F = 240$
200' Wall Bracing	B	100	.83	$q_F = 275$
Roof Girders	A	25	.96	$q_P = 315$
	B	100	.83	$q_P = 275$
Purlins	A	25	.96	$q_P = 315$
	B	0	1.00	$q_P = 330$
200' Wall Cirts & Columns	A	25	.96	$q_P = 315$
	B	0	1.00	$q_P = 330$
100' Wall Girts & Columns	A	0	1.00	$q_P = 330$
	B	25	.96	$q_P = 315$

4.3.2 Velocity Pressure Coefficient

Velocity pressure coefficients (based on height-width and height-length ratios less than 2.5) are summarized as follows:

External Pressure Coefficients, C_p

	Wind Direction	C_p	
100' Walls	A	-.7	Ref. 1, Table 7
	B	+.8 , -.5	"
200' Walls	A	+.8 , -.5	"
	B	-.7	"
Roof	A	-.7	Ref. 1, Par. 6.5.3.2.1
	B	-.7	"

Local Pressure Coefficients

	Wind Direction	$C_{p_{local}}$	
Wall Corners	A&B	-2.0	Ref. 1, Par. 6.5.3.1
Eaves	A&B	-2.4	Ref. 1, Table 10
Roof Corners	A&B	-5.0	"

Internal Pressure Coefficients

$$n = \frac{1,000}{30,000} < 0.3 \text{ and evenly distributed}$$

Ref. 1, Table 11

$$C_{pi} = \pm 0.3$$

4.3.3 Atmospheric Differential Pressures

Using the idealized pressure-time function shown in Fig. 3-1 and Bechtel computer program CE 899 resulted in a maximum differential pressure of 9 psf. Therefore, the structure can be considered fully vented (Section 3.5.2) and W_{tp} can be taken as zero. |3

4.4 Frame With Detached Sheathing

Figure 4-6 illustrates loading on a frame with sheathing partially removed. One-third of the sheathing on the windward portion of the structure is assumed to remain in place (for three-span sheathing, see Fig. 4-7). A drag coefficient of 2 is used for exposed steel members since flow around the ends is restricted by other framing members. The sheathing failure pattern will result in a low aspect ratio for remaining sheathing for which a drag coefficient of 1.2 is appropriate (see Fig. 4-4). |3

4.5 Structure With Blowout Panels

Blowout panels are installed in some structures to prevent (or minimize) differential pressure loading resulting from atmospheric pressure change. Figure 4-8 shows the pressure loading on a 100 ft. square structure just prior to blowout panel release and when the structure is subjected to maximum winds (V_{max}= 360 mph). The panels are designed to release at a pressure of 100 psf and each has sufficient area to provide full venting. As the tornado approaches the building, negative velocity pressure builds up on the leeward wall. At the same time, differential pressure from atmospheric pressure change |3

builds up, tending to force the walls outward. When the sum of these pressures reaches 100 psf, the leeward panel releases. The pressures just prior to panel release are obtained as follows:

1. Determine the value of r/R_m for a combined pressure, P_{cr}, of 100 psf (from Eq. C1-9b) for

   $V_m = 290$ mph (for $\Delta P_a = 432$ psf from Eq. C1-7a)

   $C = 0.5$

   $K = \dfrac{360}{290} = 1.24$

   $\dfrac{r}{R_m} = 1.95$

2. Determine corresponding values of P_{qr} and P_{ar} from Eqs. C1-5b and C1-7b.

   $P_{ar} = 56.4$ psf   internal pressure

   $P_{qr} = 43.6$ psf   leeward wall

   $P_{qr} = 61.1$ psf   roof and side walls

   $P_{qr} = 69.9$ psf   windward wall

The pressures before release reflect a value of $C_g = 1$ (uniform pressure distribution assumed). A value of $C_g = 1$ was also used for internal velocity pressures since the plan dimension of the blowout panel is small. Maximum external pressures correspond to a value of L equal to 100 ft.

The other panel is assumed not to release (due to initial inward velocity pressure) unless the direction of the wind reverses and the sum of the internal and external velocity pressures caused a net outward pressure of 100 psf.

4.6   Partially Vented Structures

Figure 4-9 illustrates the flow pattern and differential pressure variations in a building undergoing depressurization.

Differential pressure calculation is facilitated by first making a depressurization model for the building such as that shown in Fig. 4-10. Using this model and the pressure-time function shown in Fig. 3-1, the differential pressure-time functions between compartments one and three and between compartment 3 and outside atmosphere were calculated (using Bechtel computer program CE 899 as described in Appendix D). The resulting pressure-time functions are shown in Fig. 4-11. |3 |3

1. C_p local $= (0.1\theta - 5.0)$ $\theta \leq 30°$
        C_p local $= -2.0$ $\theta > 30°$
2. C_p local $= -2.4$ $\theta \leq 30°$
2. C_p local $= -1.7$ $\theta > 30°$
3. C_p local $= -2.0$

1 C_p local $= (0.1\theta - 5.0)$ $\theta \leq 30°$
    C_p local $= -2.0$ $\theta > 30°$
2 C_p local $= -2.4$
3 C_p local $= -2.0$

RECTANGULAR BUILDING WITH GABLED ROOF
WIND PERPENDICULAR TO RIDGE

RECTANGULAR BUILDING WITH GABLED ROOF
WIND PARALLEL TO RIDGE

FIGURE 4-1   Local Pressure Coefficients For Rectangular Building With Gabled Roof

1 C_p local $= -5.0$
2 C_p local $= -2.4$
3 C_p local $= -2.0$

W
(Least width of building)

0.1 W

WIND DIRECTION

0.1 W

RECTANGULAR BUILDING WITH FLAT ROOF

0.1 W

Overhanging eave

ROOF

WIND DIRECTION

WALL

1 pressure $= C_p$ q_F
2 pressure $= C_p$ q_F
3 pressure $= C_p$ local q_p

COMBINED EXTERNAL PRESSURES ON OVERHANGING
EAVE OF BUILDING WITH FLAT ROOF

FIGURE 4-2   Local Pressures On Rectangular Building With Flat Roof

Top chart:

PRESSURE COEFF. Cp

1.0 — .5 — 0 — -.5 — -1.0 — -1.5

0° 20° 40° 60° 80° 100° 120° 140° 160° 180°

WIND DIRECTION

Cp profile

θ° SYM. ABOUT ₵ 180°

θ + −

₵

EFFECTIVE EXTERNAL
PRESSURE COEFFICIENTS
Cp FOR CYLINDER
WITH HEIGHT/DIAMETER = 1

Bottom chart:

PRESSURE COEFF. Cp

1.0 — .5 — 0 — -.5 — -1.0

0° 20° 40° 60° 80° 100° 120° 140° 160° 180°

WIND DIRECTION

Cp profile

0° SYM. ABOUT ₵ 180°

θ + − +

EFFECTIVE EXTERNAL
PRESSURE COEFFICIENTS
Cp FOR SPHERE

ANGLE FROM STAGNATION POINT θ

FIGURE 4-3 Velocity Pressure Distribution –
Cylinders and Spheres

FIGURE 4-4   Drag Coefficient Vs. Aspect Ratio -
Suspended Rectangular Members

NOTE: External pressures on side walls $= -0.7\ q_F$

WIND PLUS INTERNAL PRESSURE   **WIND PLUS INTERNAL VACUUM**

FIGURE 4-5   Extreme Wind Velocity Pressure Distribution On Typical Building

Roof: $2A_B q_F$

Windward columns: $(2A_B + \frac{1.2}{3} hd)q_F$
          steel   sheath-
                    ing

Leeward Columns: $2A_B q_F$

A_B = Area of bare steel
d = Bay spacing
h = Height

d

Drag coefficients:
Exposed Steel $C_D = 2.0$
Remaining Sheathing $C_D = 1.2$

FIGURE 4-6   Tornado Velocity Pressure Loading On
             Steel Frame With Detached Sheathing

TYP. GIRT

ORIGINAL SIDING BEFORE TORNADO

3-SPAN SIDING
IN PLACE AFTER
TORNADO

ENDS OF SIDING

WIND

d'

d'

d'

d'

d' = TYP. GIRT
SPACING

FIGURE 4-7   Typical Sheathing Failure Pattern (3-Span Sheathing) |3

61.1

Wind
Direction

69.9   56.4   56.4   56.4   43.6

— Blowout panel —

Pressures just prior to blowout
panel release

194

Wind
Direction

220.   100   100   100   140

Pressures at maximum wind
velocity

FIGURE 4-8   Pressures on Structure Before Blowout Panel
Releases and at Maximum Wind Velocity (psf)

FIGURE 4-9   Illustration of Pressure Distribution and
Flow Pattern During Building Depressurization   3

FIGURE 4-10   Illustration of a Structure Depressurization Model |3

NOTE: INPUT TIME HISTORY PER FIG. 3-1
USING 3 Rm/V_{tr} = 9 sec
AND ΔP_a = 432 psf
STRUCTURE DEPRESSURIZATION MODEL
SHOWN IN FIGURE 4-10.

NOTE: THIS EXAMPLE IS FOR ILLUSTRATION PURPOSES ONLY.

ATMOSPHERIC PRESSURE CHANGE
TIME HISTORY FOR DESIGN IS TO BE
OBTAINED FROM SAR.

**FIGURE 4-11. DIFFERENTIAL PRESSURE-TIME HISTORY FOR
COMPARTMENTS 1 AND 3**

A P P E N D I X   A

CROSS REFERENCE LISTING
TO
AEC FORMAT

APPENDIX A

CROSS REFERENCE LISTING TO AEC FORMAT

AEC Format	Description	BC-TOP-3
	Wind Loadings	
3.3.1.1	Design Wind Velocity	2.0
3.3.1.2	Basis for Wind Velocity Selection	2.0
3.3.1.3	Vertical Velocity Distribution and Gust Factor	2.0 2.0
3.3.1.4	Determination of Applied Forces	2.0
	Tornado Loadings	
3.3.2.1	Applicable Design Parameters	3.0
3.3.2.2	Determination of Forces on Structures	3.0
3.3.2.3	Ability of Category I Structures to Perform Despite Failure of Structures not Designed for Tornado Loads	3.0

A P P E N D I X   B

NOTATION

APPENDIX B

NOTATION

a = Small dimension normal to wind.

A = Area upon which pressure is acting.

A_1 = Area (on the side of compartment 1) of the wall between compartments 1 and 2.

A_2 = Area connecting compartments 1 and 2.

A_B = Projected area of bare steel.

A_o = Area of openings

C_c = Compressibility coefficient.

C_d = Discharge coefficient.

C_v = Velocity coefficient

C = Summation of pressure coefficients for obtaining velocity pressure loading on the structure or structural element.

C_D = Drag coefficient

C_f = Net pressure coefficient.

C_L = Lift coefficient

C_p = Effective external pressure coefficient

C_{pi} = Internal pressure coefficient

$C_{p_{local}}$ = Local external pressure coefficient.

C_q = Velocity pressure factor.

C_s = Ratio of average to maximum velocity pressure of tornado wind on structure or resisting element.

F = Total force on strip of unit height.

g = Gravitational acceleration.

G = Weight flow rate of air through an orifice.

G_F = Gust factor for calculating overall structural response - extreme wind.

G_P = Gust factor for parts and portions - extreme wind.

h = Height dimension.

k = Specific heat of air at constant pressure divided by the specific heat of air at constant volume.

K = Ratio of vector sum of all velocity components to tangential velocity - tornado winds.

K_1 = Ratio of loaded plan length of structure or structural element perpendicular to the direction of tornado wind to radius of maximum winds.

K_2 = Ratio of radius r_1 to radius of maximum wind, R_m.

K_Z = Height factor describing variations of extreme wind velocity with height.

ℓ = Long dimension normal to wind.

L = Length of structure or structural element over which tornado velocity pressure is distributed.

n = Ratio of open area to solid area of wall having majority of openings.

N = Number identifying compartment or opening.

P_1 = Pressure in compartment 1.

P_2 = Pressure in compartment 2 ($P_2 < P_1$)

P_N = Pressure in compartment N.

P_a = Atmospheric pressure change.

ΔP_a = Maximum pressure change. |3

P_{ar} = Atmospheric pressure change as a function of radius.

P_{at} = Atmospheric pressure change as a function of time.

P_{ave} = Average tornado velocity pressure on structure or structural element.

P_{cr} = Combined tornado atmospheric pressure change plus velocity pressure loading as a function of radius.

P_{max} = Tornado velocity pressure at the radius of maximum wind.

P_q = Tornado velocity pressure.

P_{qr} = Tornado velocity pressure as a function of radius.

q = Effective velocity pressure.

q_F = Effective velocity pressure for calculating external pressure loading on main resisting elements and structural systems.

q_M = Effective velocity pressure for calculating internal pressure loading.

q_P = Effective velocity pressure for calculating external pressure loading on parts and portions.

r = Radius from axis of tornado.

r_1 = Radius from axis of tornado to closest end of structure or structural element ($r_1 \leq R_m$).

r_2 = Radius from axis of tornado to the far end of the structure or structural element ($r_2 \geq R_m$). | 3

R_m = Radius from center of tornado at which maximum wind velocity occurs.

t = Time.

V = Wind velocity.

V_{30} = Basic wind velocity at 30 feet above grade.

V_m = Tangential velocity component at R_m.

V_r = Radial wind velocity component.

V_t = Tangential wind velocity component.

V_{tr} = Translational velocity of tornado.

w = Least width of building.

W = Extreme wind loading.

W_N = Weight of air in compartment N.

W_t = Tornado loading.

W_{tq} = Tornado velocity pressure effects

W_{tp} = Tornado atmospheric pressure change effects.

W_{tm} = Missile impact effects.

z = Height in feet above grade.

γ_1 = Weight density of air in compartment 1.

γ_N = Weight density of air in compartment N. | 3

ρ = Mass density of air.

θ = Slope of roof in degrees from horizontal.

A P P E N D I X C

SUPPORTING DERIVATIONS

FOR

TORNADO DESIGN CRITERIA

1.0 TORNADO LOAD COMBINATIONS

The maximum combined effect of velocity pressure (W_{tq}) and atmospheric pressure change (W_{tp}) is determined from a combined set of equations for each effect expressed in terms of a common radial distance from the center of the tornado. Missile effects (W_{tm}) are combined with W_{tq} and W_{tp} considering the missile trajectory and the zone within the wind field in which maximum missile velocities are attained.

1.1 Velocity Pressure Loading

Velocity pressure loading (W_{tq}) on any structural element can be expressed in terms of velocity pressure, q, and combined pressure coefficient, C.

$$W_{tq} = \Sigma Cq\Delta A \qquad \text{(Eq. C1-1)}$$

C = summation of pressure coefficients for obtaining the velocity pressure loading on the structure or a particular element.

q = velocity pressure.

ΔA = area of portion of structure or element.

$$q = \frac{1}{2}\rho V^2 \qquad \text{(Eq. C1-2)}$$

ρ = mass density of air.
V = wind velocity.

The wind velocity, V, can be expressed in terms of r by considering V to be linearly proportional to the tangential velocity component, V_t, and assuming that V_t varies directly with radius, r, from the center of the tornado to the radius of maximum velocity, R_m, and inversely with r at radii greater than R_m (combined Rankine Vortex).

$$V_t = \frac{r}{R_m} V_m \qquad 0 < r \le R_m \qquad \text{(Eq. C1-3a)}$$

$$V_t = \frac{R_m}{r} V_m \qquad R_m \le r < \infty \qquad \text{(Eq. C1-3b)}$$

V_m = maximum tangential wind velocity.

$$V = KV_t \qquad\qquad \text{(Eq. Cl-4)}$$

$$K = \text{proportionality constant.}$$

Combining Equations Cl-1 through Cl-4, the net velocity pressure as a function of radius, P_{qr}, is:

$$P_{qr} = \frac{\rho K^2 C}{2} \left[\frac{rV_m}{R_m}\right]^2 \qquad 0 \leq r \leq R_m \qquad \text{(Eq. Cl-5a)}$$

$$P_{qr} = \frac{\rho K^2 C}{2} \left[\frac{R_m V_m}{r}\right]^2 \qquad R_m \leq r < \infty \qquad \text{(Eq. Cl-5b)}$$

The maximum velocity pressure, P_q, occurs at $r=R_m$. A dimensionless plot of P_{qr}/P_q vs. r/R_m is shown in Figure 3-2. |3

1.2 Atmospheric Pressure Change

The atmospheric pressure gradient at radius r is defined by the cyclostrophic wind equation:

$$\frac{dP_{ar}}{dr} = \frac{\rho V_t^2}{r} \qquad\qquad \text{(Eq. Cl-6)}$$

With V_t defined by Equations Cl-3a and Cl-3b, integration of Equation Cl-6 from infinity to r defines the pressure drop at radius r.

$$P_{ar} = \frac{\rho V_m^2}{2} \left(2 - \frac{r^2}{R_m^2}\right) \qquad 0 \leq r \leq R_m \qquad \text{(Eq. Cl-7a)} \quad |3$$

$$P_{ar} = \frac{\rho V_m^2}{2} \left(\frac{R_m^2}{r^2}\right) \qquad R_m \leq r < \infty \qquad \text{(Eq. Cl-7b)}$$

A dimensionless plot of P_{ar}/P_a vs. r/R_m is shown in Figure Cl-1 where P_a is the maximum pressure drop (at $r=0$).

Building depressurization and repressurization calculations require determination of pressure change with respect to time. This is accomplished by substituting $r=V_{tr}t$ into Equations Cl-7a and Cl-7b.

$$P_{at} = \frac{\rho V_m^2}{2} \left(2 - \frac{V_{tr}^2 t^2}{R_m^2} \right) \qquad 0 \leq r < R_m \qquad \text{(Eq. C1-7c)}$$ |3

$$P_{at} = \frac{\rho V_m^2}{2} \left(\frac{R_m^2}{V_{tr}^2 t^2} \right) \qquad R_m \leq r < \infty \qquad \text{(Eq. C1-7d)}$$

V_{tr} = translational velocity.

t = time (reference to center of tornado).

An illustration of pressure drop variation with time is obtained by adding a time axis to Figure C1-1. In lieu of Equations C1-7c and C1-7d, a more conservative idealized linear pressure-time curve can be used, assuming full pressure drop occurs in R_m/V_{tr} seconds (see example superimposed plot - Fig. C1-1). |3

1.3   Wind Load Plus Pressure Drop

The combined effect of velocity pressure and atmospheric pressure change is the summation of P_{qr} and P_{ar}.

$$P_{cr} = P_{qr} + P_{ar} \qquad \text{(Eq. C1-8)}$$

Substituting the values for P_{qr} and P_{ar} (as determined by Equations C1-5a, C1-5b and C1-7a and C1-7b) into Equation C1-8 yields the following formulae for P_{cr} in terms of r.

$$P_{cr} = \frac{\rho V_m^2}{2} \left[2 + \frac{r^2}{R_m^2} (K^2 C - 1) \right] \qquad 0 \leq r \leq R_m$$

$$\text{(Eq. C1-9a)}$$

$$P_{cr} = \frac{\rho V_m^2}{2} \frac{R_m^2}{r^2} (1 + K^2 C) \qquad R_m \leq r < \infty$$
$$\text{(Eq. C1-9b)}$$

Equation C1-9a shows that P_{cr} will be a maximum at r=0 or at r=R_m depending on the value of $K^2 C$. For $K^2 C < 1$, P_{cr} is a maximum at r=0 and is equal to the full value of maximum atmospheric pressure change (see Equation C1-7a). For $K^2 C > 1$, P_{cr} is a maximum at r=R_m and is equal to maximum velocity pressure effects plus one-half of maximum atmospheric pressure change.

Equation C1-9b shows that P_{cr} will be a maximum only
at $r=R_m$ (regardless of the value of K^2C) and again
will be equal to maximum velocity pressure effects
plus one-half of maximum atmospheric pressure change.

For structures with openings, loading due to atmos-
pheric pressure change may approach zero (as for com-
pletely open structures). Therefore, the load case
of velocity pressures acting alone must be considered.

These considerations result in the following design
load equations:

Velocity pressure acting alone:

$$W_t = W_{tq} \qquad\qquad \text{(Eq. C1-10)}$$

Atmospheric pressure change acting alone:

$$W_t = W_{tp} \qquad\qquad \text{(Eq. C1-11)}$$

Velocity pressure concurrent with atmospheric
pressure change:

$$W_t = W_{tq} + 0.5\, W_{tp} \qquad\qquad \text{(Eq. C1-12)}$$

These equations are identical to Equations 3-1, 3-2
and 3-4 in Section 3.

1.4   Missile Load Combinations

Missiles within a tornado wind field tend to be ejected
from the tornado. The maximum missile velocity is
obtained when the missile is near but outside of the
radius of maximum wind (R_m). For design purposes,
missiles are therefore assumed to strike a structure
at or near the radius of maximum wind at which time
the structure is subjected to full velocity pressure
effects plus one-half atmospheric pressure change. Since
the missile may also be ejected from the tornado before
striking the structure, missile effects are considered
acting independently or in combination with velocity
pressure and atmospheric pressure change. This results
in the following design load equations:

Missile acting alone:

$$W_t = W_{tm} \qquad \text{(Eq. C1-13)}$$

Missile impact concurrent with wind loads:

$$W_t = W_{tq} + W_{tm} \qquad \text{(Eq. C1-14)}$$

Missile impact concurrent with wind load and atmospheric pressure change:

$$W_t = W_{tq} + 0.5\, W_{tp} + W_{tm} \qquad \text{(Eq. C1-15)}$$

These equations are identical to Equations 3-3, 3-5 and 3-6 in Section 3.

2.0   STRUCTURE SIZE EFFECT ON VELOCITY PRESSURE LOADING

The tornado wind velocity varies with distance from the center of the tornado (r) but is assumed (conservatively) not to vary with height. The total load on a structure (or structural element) is therefore a direct function of its plan dimension, L, perpendicular to the direction of wind.

The total load will be a maximum when the radius of maximum wind speed falls within the length, L. Referring to Figure 3-3: |3

$$r_1 < R_m < r_2$$

$$L = r_2 - r_1 \qquad \text{(Eq. C2-1)}$$

An integration of the velocity pressure profile (de- |3 fined by Equations C1-5a and C1-5b) on a horizontal strip between limits of r_1 and r_2 results in the following expression for total force on a unit width strip of length, L.

$$F = \frac{\rho\, CK^2 V_m^2}{2} \left[\frac{4}{3} R_m - \frac{r_1^3}{3R_m^2} - \frac{R_m^2}{r_2} \right]$$

$$0 \le r_1 \le R_m$$
$$R_m \le r_2 < \infty \qquad \text{(Eq. C2-2)}$$

From examination of Equation C2-2, it is found that F is a maximum when the structure is positioned such that $r_1 = R^2_m/r_2$.

Making the following substitutions into Equation C2-2;

$$K_2 = \frac{-K_1 + \sqrt{K_1^2 + 4}}{2} \qquad \text{(Eq. C2-3)}$$

$$L = K_1 R_m$$

$$r_1 = K_2 R_m$$

$$P_{ave} = \frac{F}{L}$$

$$P_{max} = \frac{\rho C K^2 V_m^2}{2}$$

The ratio of average pressure to maximum pressure is:

$$\frac{P_{ave}}{P_{max}} = \frac{4}{3K_1} - \frac{K_2^3}{3K_1} - \frac{1}{(K_1 + K_2)K_1} \qquad \text{(Eq. C2-4)}$$

A plot of Equation C2-4 (P_{ave}/P_{max} vs. K_1) is shown in Figure 3-3. |3

Knowing the maximum velocity pressure (P_{max}) and the ratio of structure length to radius of maximum wind velocity ($L/R_m = K_1$), the average pressure (P_{ave}) can be determined directly from Figure 3-3. The value of R_m is specified in the plant SAR. |3

FIGURE Cl-1 Atmospheric Pressure Change Variations With Radius And Time

The figure shows a graph with:

Top axis: Time* (sec) with values 1, 2, 3, 4, 5, 6, 7, 8, 9

Left axis: P_{ar}/P_a with values 0.0, 0.1, 0.2, 0.3, 0.4, 0.5, 0.6, 0.7, 0.8, 0.9, 1.0

Bottom axis: $\frac{r}{R_m}$ with values 0.5, 1, 1.5, 2, 2.5, 3

Labels within the graph:
- 3 sec.
- Idealized Curve
- Curve based on Equations Cl-7a through Cl-7d

*Time scale based on a value of

$$\frac{R_m}{V_{tr}} = 3.0 \text{ sec.}$$

This value was selected for illustrative purposes only. (Design values of R_m and V_{tr} to be obtained from plant SAR.)

ω

A P P E N D I X D

COMPUTER PROGRAM

FOR

BUILDING DEPRESSURIZATION

BECHTEL CORPORATION PROGRAM CE 899

APPENDIX D

COMPUTER PROGRAM

FOR

BUILDING DEPRESSURIZATION

BECHTEL CORPORATION PROGRAM CE 899

1.0 PROGRAM CAPABILITY

Bechtel Corporation program CE 899 is used to calculate differential pressures between compartments within buildings and across interior and exterior surfaces of a building subjected to tornado-induced time-dependent atmospheric pressure change. |3

1.1 Theory and Equations

Laws for quasi-steady, one-dimensional motion of an |3 ideal compressible gas are used to calculate the flow of air in the structure and the differential pressure history with the three-dimensional effects taken into account by a factor of safety. |3

The weight flow rate of air and the relationship between pressure and air weight-density are based on an adiabatic process.

1.1.1 Weight Flow Rate

The weight flow rate, G, of air passing through an orifice is defined as follows (from Ref. 20):

$$G = C_v C_c A_2 [2g\gamma_1 (p_1 - p_2)]^{\frac{1}{2}} \qquad \text{(Eq. D-1)}$$

$$C_v = C_d [1 - (A_2/A_1)^2]^{-\frac{1}{2}} \qquad \text{(Eq. D-2)}$$

$$C_c = \left[\left(\frac{P_2}{P_1}\right)^{2/k} \left(\frac{k}{k-1}\right) \left\{ \frac{1-\left(\frac{P_2}{P_1}\right)^{\frac{k-1}{k}}}{1-\left(\frac{P_2}{P_1}\right)} \right\} \left\{ \frac{1-\left(\frac{A_2}{A_1}\right)^2}{1-\left(\frac{A_2}{A_1}\right)^2 \left(\frac{P_2}{P_1}\right)^{2/k}} \right\} \right]^{\frac{1}{2}}$$

$$\text{(Eq. D-3)}$$

A_1 = Area (on the side of compartment 1) of the wall between compartments 1 and 2.

A_2 = Area connecting compartments 1 and 2.

C_c = Compressibility coefficient.

C_d = Discharge coefficient (which is a function of Reynolds number - Ref. 20, p. 125).

C_v = Velocity coefficient.

g = Gravitational acceleration.

k = $\dfrac{\text{Specific heat of air at constant pressure}}{\text{Specific heat of air at constant volume}}$ = 1.4

P_1 = Pressure in compartment 1.

P_2 = Pressure in compartment 2 $(P_2 < P_1)$

γ_1 = Weight density of air in compartment 1.

Equation D-1 is valid if the flow through the orifice is subcritical. The flow is subcritical when the conditions of Equation D-4 are satisfied (Ref. 21).

$$1 > \frac{P_2}{P_1} > 0.528 \qquad \text{(Eq. D-4)}$$

1.1.2 Pressure Weight-Density Relationship

The following relationship between pressure and weight-density is assumed to be constant: |3

$$P_N \gamma_N^{-k} = \text{a constant} \qquad \text{(Eq. D-5)}$$

P_N = Pressure in compartment N.

γ_N = Weight-density of air in compartment N.

Within each time increment, Δt, the flow is assumed to be steady and subcritical. The weight of air in compartment N, W_N, at time t_{i+1} is therefore:

$$W_N(t_{i+1}) = W_N(t_i) + [G_{N(in)}(t_i) - G_{N(out)}(t_i)]\Delta t$$

$$\text{(Eq. D-6)}$$

The weight flow rate, G_N, is defined by Equation D-1. Since the volume of each compartment remains constant, the ratio of weight densities is equal to the ratio of weights:

$$\gamma_N(t_{i+1})/\gamma_N(t_i) = W_N(t_{i+1})/W_N(t_i) \qquad \text{(Eq. D-7)}$$

The pressure in compartment N at time t_{i+1} is therefore, (from Equation D-5):

$$P_N(t_{i+1}) = [W_N(t_{i+1})/W_N(t_i)]^k P_N(t_i) \qquad \text{(Eq. D-8)}$$

1.1.3   Three-Dimensional Effects

It is recognized that the one-dimensional analysis yields conservative differential pressures on all interior walls of a building. A 1.20 factor of safety shall be applied to the computed differential pressures on exterior walls to account for possible non-conservatism due to the three-dimensional effects.

1.2   Computer Operations

Equations D-1, D-6 and D-8 are used in the program along with the input atmospheric pressure change time-history, the description of blowout panels (if present), the geometry of the structure, and the order of interconnecting the compartments to evaluate the differential air pressures on internal and external walls.

During each time increment (usually 0.01 second or less), the air flowing from connecting compartments into compartment N is computed, taking each connecting compartment separately. The pressure is held constant in compartment N and the flow from all connecting compartments is computed. Then, half of the computed inflow air from each connecting compartment is added to the air in compartment N. The flow of air into compartment N is computed again for the same increment (at time t_i), with an adjusted pressure and the adjusted amount of air in compartment N is calculated before proceeding to the next time increment (at time t_{i+1}).

If a blowout panel exists in a compartment, the differential pressure is checked to see whether the design pressure has been exceeded. If it has been exceeded, the area of the blowout panel becomes a new outlet for the compartment to a connected compartment or to the outside atmosphere.

1.3 Input Data

The input data required for the program are as follows:

1. Total transient time and time integration interval.
2. Table of weight density of air vs. pressure.
3. Table of atmospheric pressure vs. time.
4. Number of compartments, number of ports, number of intercompartment connections, initial pressure for all compartments and ports, velocity coefficient, C_v and compressibility coefficient, C_c. If not specified, the values of $C_v = 0.6$ and $C_c = 0.98$ will be used in the program.
5. Compartment and connectivity list, including the compartment volume and whether it is connected to a port.
6. Port and port area table giving initial port area, blowout panel area and blowout pressure.
7. Intercompartment area table giving initial connecting area, blowout panel area and blowout pressure.

Most of the data required for the program can be established from the geometry of the structure and the interconnection of compartments. Values of C_v and C_c can be assigned using data for standard orifices such as those |3 contained in References 22 and 23 as a guide.

1.4 Example

An example of a structure depressurization model defining compartment volumes, connectivity, ports and interior vents is described in Section 4-6 and Figure 4-10. A typical differential pressure-time history resulting from an atmospheric pressure-time function (Figure 3-1) |3 applied to this model is shown in Figure 4-11.

A P P E N D I X   E

REFERENCES

APPENDIX E

REFERENCES

1. "American National Standard Building Code Requirements for Minimum Design Loads in Buildings and Other Structures", American National Standards Institute, A58.1-1972.

2. ASCE Committee Report, "Wind Forces on Structures", Transactions of the ASCE, Paper No. 3269, 1961.

3. Bechtel Power Corporation, "Design of Structures for Missile Impact", Topical Report BC-TOP-9, Rev. 1, July, 1973.

4. "Seismic Design Classification", Regulatory Guide 1.29, Directorate of Regulatory Standards, U. S. Atomic Energy Commission, Revision 1, August 1973. |3

5. Irish, K., and R. Cochrane, "Wind Vibration of Chimneys", ACI Journal, September, 1972.

6. Kessler, E., (of National Severe Storms Laboratory), letter to H. Denton, on the Subject of windspeed and regional characteristics of tornadoes, April 25, 1973.

7. Bechtel Corporation, "Design Criteria for Nuclear Power Plants Against Tornadoes", Topical Report B-TOP-3, March 12, 1970.

8. Shanahan, J. A., "Engineering Report on the Lubbock Tornadoes of May 11, 1970", Bechtel Corporation, Power and Industrial Division, San Francisco, Calif., October, 1972.

9. Flora, S. D., "Tornadoes of the United States", University of Oklahoma Press, Norman, Oklahoma, 1953.

10. Reynolds, G. W., "Venting and Other Building Practices as Practical Means of Reducing Damage from Tornado Low Pressures", Bulletin, American Meteorological Society, January, 1958.

11. Fujita, T. T., "Estimate of Maximum Windspeeds of Tornadoes in Southernmost Rockies", SMRP Research Paper No. 105, The University of Chicago, June, 1972.

12. Fujita, T. T., "Estimate of Maximum Windspeeds of Tornadoes in Three Northwestern States", SMRP Research Paper No. 92, The University of Chicago, 1970.

13. Fujita, T. T., "A Detailed Analysis of the Fargo Tornadoes", U. S. Department of Commerce, Weather Bureau, Research Paper No. 42, December, 1960.

14. Fujita, T. T., D. L. Bradbury, and P. G. Black, "Estimation of Tornado Wind Speeds from Characteristic Ground Marks", SMRP Research Paper No. 69, The University of Chicago, 1967.

15. Fujita, T. T., D. L. Bradbury, and C. F. Van Thullerar, "Palm Sunday Tornadoes of April 11, 1965", Monthly Weather Review, 98, No. 1, 1970, pp. 29-69.

16. Hoecker, W. H., "Wind Speed and Air Flow Patterns in the Dallas Tornado of April 2, 1957", Monthly Weather Review, May, 1960, pp. 167-180.

17. Lewis, W., and P. T. Perkins, "Recorded Pressure Distribution in the Outer Portions of a Tornado Vortex", Monthly Weather Review, December, 1953.

18. McDonald, J. R., "Structural Response of a Twenty Story Building to the Lubbock Tornado", Texas Technical University, TTU-SSR-01, October, 1970.

19. Mehta, K. C., et al., "Response of Structural Systems to the Lubbock Storm", Texas Technical University, TTU-SSR-03, October, 1971.

20. Binder, R. C., Fluid Mechanics, Second Edition, Prentice-Hall, Inc., New York, New York, 1949.

21. Eshbach, O. W., Handbook of Engineering Fundamentals, Second Edition, John Wiley & Sons, Inc., 1952.

22. "Flow of Fluids Through Valves, Fittings, and Pipe", Technical Paper No. 410, Crane Co., 300 Park Avenue, New York, New York, 10022, 1969.

23. Perry, J. A., "Critical Flow Through Sharp-Edged Orifices", Trans., ASME, October, 1949, pp. 757-764.

|3